



MUNICIPAL CORPORATION OF DELHI

PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SINGH VERMA NIQAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No. DHOWZ/2026/D- 257

Dated: 25/06/26

HEALTH CERTIFICATE

In further continuation of this, a School Health Certificate was issued vide letter no DHOWZ/2025/D-2097, dated 28.11.2025. The school premises were re-inspected by officials of the Public Health Department in the presence of school management, and found to be in sanitary and hygienic condition from a health point of view. The details are as follow

Name of the school: S.M. Arya Public School

Address of School Punjabi Bagh (West), New Delhi-110026

Shifts: ONE Timing: MORNING

No. of Students: Boys :- 766 Girls:- 509 Total:- 1275

No. of Staff (Teachers): Female :- 52 Male:- 09 Total:- 61

Non-Teaching (Staff) : Female :- 09 Male:- 05 Total:- 14

That the accommodation provided for the class rooms as calculated.

- | | |
|---|-----------|
| (A) On floor space is sufficient | Yes |
| (B) On Cubic space is sufficient | Yes |
| That the classrooms are well ventilated | Yes |
| That the classrooms are kept neat and clean | Yes |
| That the classrooms are well lighted | Yes |
| That the drinking water is wholesome | Wholesome |
| That the latrines arrangement is adequate and there are sufficient latrines | |
| That urinals arrangement is adequate and there are sufficient urinals | |

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school premises. This certificate has no bearing structure stability/ unauthorized construction and fire safety. This certificate is valid for one year from the date of issue.



25/6/26
DY. HEALTH OFFICER
WEST ZONE
Dy. Health Officer
West Zone
MCD

"STOP CORONA VIRUS- Wear Mask/ Wear Hand Glove/ Maintain Social Distance"

DELHI JAL BOARD : (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085.



(ISO Certified 9001:2015)

THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY

Water samples collected from S1:- Before R/o, S2:- After R/o of S.M. Arya Public School, Punjabi Bagh, Delhi vide challan no. 158 dated 17.09.2025.

S. No.	PARAMETERS	UNITS	B.I.S.10500:2012		S1	S2
			Desirable	Permissible		
1.	Date of Collection	--	---	---	22.09.2025	22.09.2025
2.	Date of Analysis	--	---	---	24.09.2025	24.09.2025
3.	Colour	C.U.	5	15	2 C.U.	2 C.U.
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U.	1.0	5.0	2.86	1.95
6.	pH value	--	6.5 to 8.5	N.R.	7.4	7.8
7.	Electrical Conductivity	µs/cm	----	----	283.0	269.0
8.	Total Dissolved Solid	(mg/l)	500	2000	183.95	174.85
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	(mg/l)	----	----	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	82.0	81.0
11.	Total Hardness	(mg/l)	200	600	115.0	113.0
12.	Calcium Hardness	(mg/l)	----	----	80.0	80.0
13.	Magnesium Hardness	(mg/l)	---	----	35.0	33.0
14.	Calcium as Ca	(mg/l)	75	200	32.0	32.0
15.	Magnesium as Mg	(mg/l)	30	100	8.4	7.92
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate NO ₃	(mg/l)	45	N.R.	3.93	3.34
19.	Sulphate (SO ₄)	(mg/l)	200	400	31.03	29.45
20.	Chloride (Cl)	(mg/l)	250	1000	19.0	16.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.03	0.01
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.56	0.32
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.75	Nil
BACTERIOLOGICAL EXAMINATION						
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0	0	0	0

Remarks: On the basis of tested parameters, water sample 'S1' & 'S2' confirms to drinking water specification IS.10500:2012 & may be used for drinking purpose.

M.C. 19
25/9/25
Asstt. Chemist



Chemist/Bacteriologist

